



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10932

1. OWNER Las Vegas Paving ADDRESS AT WELL LOCATION Harmon ST
 MAILING ADDRESS 4420 S. Decatur Between Harmon + McLeod
Las Vegas, NV 89103

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 23-24 T 21 N/S R 61 E County _____
 PERMIT NO. DW-1024 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Temp

4. PROPOSED USE Dewaterers WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------------|--------------|-----------|-----------|------------|
| <u>Fill sand</u> | | <u>0</u> | <u>2</u> | <u>2</u> |
| <u>Silt, clay</u> | | <u>2</u> | <u>16</u> | <u>14</u> |
| <u>Silt, sand + clay</u> | | <u>16</u> | <u>25</u> | <u>9</u> |
| <u>Silt, sand w/gravel</u> | | <u>25</u> | <u>32</u> | <u>7</u> |
| <u>Silty clay</u> | | <u>32</u> | <u>36</u> | <u>4</u> |
| <u>clay</u> | | <u>36</u> | <u>40</u> | <u>4</u> |

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>8</u> | | <u>Sch 40</u> | <u>0</u> | <u>40</u> |

Perforations:
 Type perforation Saw Cut
 Size perforation 1030

From 20 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 40 feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 3-7, 1995
 Date completed 3-7, 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge:
 Name Griffin Contract Dewatering
 Address 536 E Maitland
Ontario CA 91761
 Nevada contractor's license number issued by the State Contractor's Board 0031246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968T
 Signed Greg Deally
 By driller performing actual drilling on site or contractor
 Date 3-7-95

RECEIVED
 MAR 20 1995
 Div. of Water Resources
 Branch Office - Las Vegas NV