WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52756
Permit No.
Basin 212

NOTICE OF INTENT NO. 17413

1. OWNER Tommy Ford
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5606 A Sandhill

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 21 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 161-308-010-021 Parcel No. 601 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cleaned well | | | | |
| to 83' and | | | | |
| pumped neat | | | | |
| cement from | | | | |
| 83' to surface. | | | | |

Date started 5-17, 19 96
Date completed 5-21, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Well Services (Contractor)
Address 6475 Gary Ave (Contractor)
Las Vegas, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 022311
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963
Signed Pyndall Couch (By driller performing actual drilling on site or contractor)
Date 6-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627