

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17416

1. OWNER Tommy Ford ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SE 1/4 Sec. 30 T. 21 N/S R. 62 E. CLARK County  
 PERMIT NO. 161-308-010-021 Issued by Water Resources Parcel No. 45 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND, CLAY AND GRAVEL.</u>		<u>0</u>	<u>140</u>	<u>140</u>
<u>CALICHE.</u>		<u>140</u>	<u>145</u>	<u>5</u>
<u>CLAY</u>		<u>145</u>	<u>163</u>	<u>18</u>
<u>CALICHE</u>		<u>163</u>	<u>167</u>	<u>4</u>
<u>CLAY</u>		<u>167</u>	<u>195</u>	<u>28</u>
<u>SAND</u>		<u>195</u>	<u>200</u>	<u>5</u>
<u>CLAY</u>		<u>200</u>	<u>310</u>	<u>110</u>
<u>CLAY + GRAVEL.</u>		<u>310</u>	<u>340</u>	<u>30</u>
<u>CEMENTED GRAVEL.</u>		<u>340</u>	<u>400</u>	<u>60</u>

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>400</u>

Perforations:  
 Type perforation FACTORY SAW.  
 Size perforation 1 7/8 x 2 1/2  
 From 340 feet to 400 feet  
 From 140 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
85  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 85 feet to 400 feet


9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow 60 G.P.M. 10 P.S.I.  
 Water temperature 70 °F Quality FAIR

Date started 5-28, 1996  
 Date completed 6-5, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WATER WELL SERVICES Contractor  
 Address 6475 GARY AVE Contractor  
LAS VEGAS, NV. 89139  
 Nevada contractor's license number issued by the State Contractor's Board 022311  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963  
 Signed Samuel Couch  
 By driller performing actual drilling on site or contractor  
 Date 6-10-96



918  
918

