WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52867
Permit No. 2071
Basin 216

NOTICE OF INTENT NO. 16133

1. OWNER Silver State Disposal
MAILING ADDRESS Post Office Box 98508
Las Vegas, NV 89193

ADDRESS AT WELL LOCATION Apex

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 185 N/S R. 64 E County

PERMIT NO. 2071 (Issued by Water Resources) | 540-290-029 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Muddy Creek Formation		0	1500	1500
Limestone Dolomite inter bedded shales & gypsum				
Continuation of Perforated Sections				
		1260	1280	
		1220	1240	
		1180	1200	
		1140	1160	
		1100	1120	
		1060	1080	
		1020	1040	

Date started Jan 8, 1996
Date completed June 7, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	325	8

8. WELL CONSTRUCTION
Depth Drilled 1500 Feet Depth Cased 1500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18"	Inches	51	Feet	1500	Feet
26	Inches	0	Feet	51	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Milled Slots
Size perforation 1/8 x 2 1/2 12 Rows
From 1460 feet to 1480 feet
From 1420 feet to 1440 feet
From 1380 feet to 1400 feet
From 1340 feet to 1360 feet
From 1300 feet to 1320 feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 645 feet below land surface
Artesian flow G.P.M. S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co. (Contractor)
Address 4185 W. Harmon (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 42864

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851 1901

Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date 6/28/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627