WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52931
Permit No.
Basin 162

NOTICE OF INTENT NO. 14932

1. OWNER ELWOOD JOHN FOERST
MAILING ADDRESS 2420 E MANSE
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION
2420 E MANSE

2. LOCATION SE 1/4 NW 1/4 Sec. 1 T 21S N/S R 53E E NYE County
PERMIT NO. _____ Issued by Water Resources
44-102-08 Parcel No.
MANKO SUBDIVISION Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	19	19
GREY CLAY		19	32	13
WHITE CLAY		32	46	14
GREY CLAY	X	46	59	13
LIGHT GREY CLAY	X	59	73	14
LIGHT GREY CLAY	X	73	89	16
DARK GREY CLAY	X	89	111	22
LIGHT GREY CLAY	X	111	122	11
BEIGH POPCORN	X	122	140	18

RECEIVED AUG 7 1996 LAS VEGAS OFFICE

Date started 7/20/96, 19__
Date completed 7/21/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.50.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12"	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation TORCH
Size perforation .25 X 6
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 90 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address HC 78 BOX 80036 Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Tony Strickland
By driller performing actual drilling on-site or contractor
Date 8-5-96