WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53094
Permit No.
Basin 105

NOTICE OF INTENT NO. 32733

1. OWNER 5 Creek LLC
MAILING ADDRESS Box 2410 Minden, NV 89423
ADDRESS AT WELL LOCATION NONE

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 12 N. S. R. 19 E. Douglas County
PERMIT NO. W 458 6/929 (Issued by Water Resources) | NA (Parcel No.) | Job's Peak Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hillside AL		0	6	6
DG & Med Blders		6	66	60
Hard To soft DG	X	66	130	64
V Soft DG w V Fine sand well Sorted	X	130	135	5
V consistent, Fine To Med Grain DG w Minor, V Thin, Lt Brwn Clays	X	135	400	65
Drilled 8" test well To 311'				
Drilled Production well To 400'				

Date started 4/24, 1996
Date completed 7/27, 1996

RECEIVED 96 SEP 16 AM 1:08 STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100-200		4

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
15	0	92
14	92	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		1/4	+2	400

Perforations:
Type perforation Sawcut
Size perforation 3X 3/32
From 95 feet to 115 feet
From 150 feet to 170 feet
From 180 feet to 200 feet
From 245 feet to 265 feet
From 265 feet to 285 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 92
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 92 feet to 400 feet

9. WATER LEVEL
Static water level 130± feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Colo °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Leisch (By driller performing actual drilling on site or contractor)
Date 8/21/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627