

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2727

1. OWNER A+A CONSTRUCTION ADDRESS AT WELL LOCATION: EAST VALLEY RD
 MAILING ADDRESS P.O. BOX 995 GARDNERVILLE
MINDEN, NV 89423

2. LOCATION NE 1/4 NW 1/4 Sec. 12 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 60603 23-200-09 TESSEN ESTATES

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/GRAVEL		0	139	139
SAND + GRAVEL		139	166	27
SANDY CLAY w/GRAVEL		166	183	17
SAND + GRAVEL	✓	183	208	25
SANDY CLAY w/GRAVEL		208	234	26
SAND + GRAVEL	✓	234	242	8
SANDY CLAY w/GRAVEL		242	253	11
SAND + GRAVEL	✓	253	282	29
SANDY CLAY w/GRAVEL		282	304	22
SAND + GRAVEL	✓	304	319	15
SANDY CLAY		319	340	21
CEMENTED GRAVEL	✓	340	434	94
SANDY CLAY w/GRAVEL		434	472	38
CEMENTED GRAVEL	✓	472	500	28

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)
 From To
8 3/4 Inches 0 Feet 500 Feet
18 Inches 0 Feet 460 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>	<u>33 1/2</u>	<u>.250</u>	<u>+3</u>	<u>460</u>

Perforations:
 Type perforation SCREEN
 Size perforation .050
 From 160 feet to 320 feet
 From 340 feet to 440 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 460 feet

9. WATER LEVEL
 Static water level: 11.9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 6-6, 1996
 Date completed 8-7, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>100+</u>	<u>—</u>	<u>20</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1997
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-7-96