

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1608

PRINT OR TYPE ONLY

OWNER Charles Kingen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Pahrump, Nev. 89041

2. LOCATION NW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 34 T. 19-S N/S R. 53 E. Nye County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	12	12
Brown Sandy Clay		12	38	26
Brown Clay with Gravel		38	74	36
Brown Sandy Clay	x	74	96	22
Hard Shale		96	104	8
Gray Clay	x	104	130	26
Brown Clay	x	130	160	30

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 160 feet
 Casing record 160 ft. of 8 in casing
 Weight per foot 15 lbs. Thickness .156

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 160 feet

Perforations:
 Type perforation torch cut
 Size perforation 3/8 in width 8 in long
 From 80 feet to 160 feet
 From _____ feet to _____ feet

RECEIVED

MAR 5 1984

Div. of Water Resources
 Branch Office — Las Vegas, Nev.

Date started February 17, 1984
 Date completed February 17, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 58 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address ST. RT. BOX 5231 Contractor
 Nevada contractor's license number 7484
 Nevada contractor's drillers number _____
 Nevada driller's license number 725 Actual Driller
 Signed Charles Nyberg Contractor
 Date February 22, 1984

BAILER TEST

G.P.M. 20 gals. Draw down 4 feet 1/4 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours