WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

#0320

In Book

OFFICE USE ONLY
Log No. 53537
Permit No.
Basin

1. OWNER Gil Salinas ADDRESS 4335 N Chieftain, L.V.

2. LOCATION NE ¼ SE ¼ Sec. 6 T. 20S N/S R. 60 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Gravel		0	3	
Cemented Gravel		3	5	
Sand Gravel		5	18	
Cemented Gravel		18	240	
Clay Gravel		240	485	
Gravel & Water		485	516	

RECEIVED
OCT 22 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Oct 12, 19 82
Date completed Oct. 19, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 516 feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
8 5/8 inches	+1 feet	516 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory 4 Row
Size perforation ¼"
From 480 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 335 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H Dimick
Address 4131 Bradley Rd, L.V.
Nevada contractor's license number 10062
Nevada driller's license number 452
Signed V. H. Dimick
Date Oct 20, 1982

USE ADDITIONAL SHEETS IF NECESSARY

O-627