WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53586
Permit No.
Basin 162

NOTICE OF INTENT NO. 14945

1. OWNER Jack Brandt
MAILING ADDRESS 3361 E. Kellogg
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
3361 E. Kellogg

2. LOCATION SE 1/4 SW 1/4 Sec. 18 T 21S N/S R 54E E Nye County
PERMIT NO. Issued by Water Resources
45-261-05 Parcel No.
Green Saddle Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WHITE CLAY		0	19	19
BROWN CALICHIA		19	37	18
GREY CALICHIA		37	56	19
LIGHT GREY CALICHIA		56	75	19
BROWN POPCORN	X	75	96	21
BROWN CALICHIA	X	96	115	19
LIGHT BROWN CLAY	X	115	140	25

DCNR/DWR Received SEP 11 1996 Division of Water Resources

Date started 9/7/96, 19__
Date completed 9/9/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	13	188	0	140

Perforations:
Type perforation TORCH
Size perforation .25 X 6
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address HC 78 BOX 80036 Contractor
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 9. 9. 96