WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53592
Permit No.
Basin 162

NOTICE OF INTENT NO. 14935

1. OWNER BILL ROBERTS
MAILING ADDRESS 4901 E SAVOY
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION
4901 E SAVOY

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 21S N/S R 54E E NYE County
PERMIT NO. Issued by Water Resources
45-293-04 Parcel No.
GREEN SADDLE RANCH Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	19	19
SAND & GRAVEL		19	32	13
BROWN CLAY		32	48	16
GREY CALICHIA	X	48	62	14
GREY CALICHIA & ROCKS	X	62	80	18
HARD BROWN CALICHIA	X	80	99	19
BROWN CALICHIA	X	99	121	22
BROWN CALICHIA	X	121	138	17
HARD BROWN CALICHIA	X	138	155	17

Date started 8/21/96, 19__
Date completed 8/22/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.50

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	155 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	155

Perforations:
Type perforation TORCH
Size perforation .25 X 6
From 115 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 105 feet to 155 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address HC 78 BOX 80036 Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 8·23·96

DOMESTIC AUG 28 1996