WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53593
Permit No.
Basin 162

NOTICE OF INTENT NO. 17978

1. OWNER FRYE, LINDA
MAILING ADDRESS 8451 OLD SPANISH TRAIL
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION
8451 OLD SPANISH TRAIL

2. LOCATION SE 1/4 NW 1/4 Sec. 28 T 21S N/S R 54E E NYE County

PERMIT NO. _____ Issued by Water Resources | 45-371-12 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	15	15
CEMENTED GRAVEL		15	21	6
GRAVEL& CLAY		21	74	53
GRAVEL	TR	74	78	4
CLAY & GRAVEL		78	129	51
LIMESTONE	WB	129	146	17
FRACTURED LIMESTONE	WB	146	150	4

DCNF/DWR Received SEP 5 1996 Las Vegas Office

Date started 7/22/96 , 19__
Date completed 7/26/96 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	150

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal _____
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 5 G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dem
By driller performing actual drilling on-site or contractor

Date 8/23/96