

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 53637

Rec. No. \_\_\_\_\_ 19. \_\_\_\_\_

Well No. \_\_\_\_\_

Permit No. \_\_\_\_\_

*Do not fill in*

Owner H.E. Curtis Driller BERT HALLGREN

Address \_\_\_\_\_ Address 910 E COLLEGE Lic. No. 63

Location of well: SE 1/4 SE 1/4 Sec 12, T. 20N/S, R. 60E, in Clark County

or Big Sky National Air Port

Water will be used for Domestic Total depth of well 105

Size of drilled hole 8" Weight of casing per linear foot 26 #

Thickness of casing 1/2" Temp. of water \_\_\_\_\_

Diameter and length of casing 8u 30f  
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure \_\_\_\_\_

If nonflowing well give depth of standing water from surface 30'

If flowing well describe control works \_\_\_\_\_  
(Type and size of valve, etc.)

Date of commencement of well ~~Oct 25~~ Sep 25 52 Date of completion of well Oct 2 52

Type of well rig 71 Star

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	Surface
5	15	10	Gyp
15	60	45	Clay
60	65	5	Gravel F Water
65	100	35	Clay Yellow
100	105	5	Gravel

Water-bearing Formation, Casing Perforations, Etc.

---

Chief aquifer (water-bearing formation)

from 100 to 105 ft.

Other aquifers \_\_\_\_\_

---

First water at 60 feet.

Casing perforated

from 100 to \_\_\_\_\_ ft.

Size of perforations \_\_\_\_\_



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	30	30	Cemented

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Bert Hargrove  
Well Driller

By.....

License No. 63

Dated 11 20, 19 52

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---

01/29/2016 by DSB

