

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15430

1. OWNER James Zornie ADDRESS AT WELL LOCATION Brent St
MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 19 N/S R. 60 E Clark County
PERMIT NO. 12511323002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	175	175
GRAVEL w/CLAY	MIN	175	180	5
CLAY		180	280	100
GRAVEL Lense	MIN	280	285	5
CLAY		285	460	175
BAND CLAYSTONE	X	460	500	40
CLAY		500	570	70
BAND CLAYSTONE	X	570	620	50

8. WELL CONSTRUCTION
Depth Drilled 620 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
12 1/4 Inches _____ Feet 620 Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>.188</u>	<u>±6'</u>	<u>620'</u>

Perforations:
Type perforation Torch
Size perforation 14" x 10"
From 540 feet to 620 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 620 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.
Water temperature cool °F Quality OK

Date started 8/20 1996
Date completed 9/31 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR TEST</u>	<u>250 PSI @ 45CFM @</u>	
<u>620'</u>	<u>35-40</u>	<u>AFTER 3 hrs.</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mitchell Enterprises Contractor
Address 425080 Anville #262 Contractor
Dean Mitchell
Nevada contractor's license number 42266
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Dean Mitchell
By driller performing actual drilling on site or contractor
Date 9/14/96

