

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15094

1. OWNER Wheeler ADDRESS AT WELL LOCATION S. Polaris
 MAILING ADDRESS S. Polaris L.O. NV 89103
 2. LOCATION NW 1/4 NW 1/4 Sec. 17 T. 21 N. R. 6 E Clark County
 PERMIT NO. MO-2740 Parcel No. 162-17-102-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY GRAVEL		0	2'	2'
SILTY SAND		2	5'	3'
CLAYEY SAND		5	7'	2'
CALICHE		7	11 1/2'	4 1/2'
CLAYEY SAND w/ GRAVEL		11 1/2'	20'	8 1/2'
CALICHE		20'	24'	4'
SANDY CLAY		24	30	6'

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 29 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" To 30'
 Inches 0 Feet 30'
 Inches 0 Feet 0
 Inches 0 Feet 0

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>			<u>0</u>	<u>9</u>

Perforations:
 Type perforation Slotted
 Size perforation 1.020
 From 9 feet to 29 feet
 From 9 feet to 9 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 9
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 8 feet to 30 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature 0 °F Quality 0

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Terracon Consultants Contractor
 Address 4343 S. Polaris Contractor
L.O. NV. 89103
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2017
 Signed Kenneth A. Kutama
 By driller performing actual drilling on site or contractor
 Date

Date started 8-7, 1996
 Date completed 8-7, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			