WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54211
Permit No. 56391
Basin 212

NOTICE OF INTENT NO. 15785

1. OWNER Ron Ayers & Terry McNaulty
MAILING ADDRESS P.O. Box 81260
Las Vegas Nev. 89180

ADDRESS AT WELL LOCATION 8285 Garenime
Las Vegas, NV

2. LOCATION NE ¼ SE ¼ Sec. 11 T. 19 N/S R. 60 E. Clark County

PERMIT NO. 56391 (Issued by Water Resources) 12511 303 008 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cleache Clay		0	20	
Brown Clay		20	30	
Cleache		30	65	
Brown Clay		65	75	
Cleache		75	175	
Sand Gravel		175	185	
Clay		185	245	
Cleache		245	275	
Clay		275	290	
Sand Gravel		290	305	
Clay		305	400	
Sand Gravel		400	450	
Clay		450	470	
Sand Gravel		470	500	

DCNR/DWR Received SEP 20 1996 LAS VEGAS OFFICE

Date started 6-20, 1996
Date completed 7-7, 1996

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	500 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	188	+2	500

Perforations:
Type perforation Torch
Size perforation ¼ X 12
From 440 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 75
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 500 feet to 425 feet

9. WATER LEVEL
Static water level 178 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Murrell Redding JR (Contractor)
Address 8170 Haven (Contractor)
Las Vegas, NV 89123

Nevada contractor's license number issued by the State Contractor's Board 38155

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798

Signed Murrell Redding Jr (By driller performing actual drilling on site or contractor)

Date 8-25-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627