

OFFICE USE ONLY
 LOG NO. 54408
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 7096

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Jeffery Bilbro ADDRESS AT WELL LOCATION 8465 WESTWIND RD
 MAILING ADDRESS 5525 W. Wigwam
Las Vegas, Nevada 89118
 2. LOCATION SE 1/4 NW 1/4 Sec. 13 T 22 N/S R. 60 E Clark County
 PERMIT NO. 170-13-201-023 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	
Cemented Gravel		5	7	
Gravel		7	13	
Cemented Gravel		13	15	
Gravel		15	19	
Cemented Gravel		19	20	
Gravel		20	28	
Cemented Gravel		28	31	
Gravel		31	45	
Cemented Gravel		45	50	
Gravel		50	75	
Cemented Gravel		75	80	
Reddish Sandstone Gravel		80	175	
Cemented Gravel		175	260	
Reddish Sandstone Gravel		260	405	
Cemented Gravel & Water		405	410	
Cemented Gravel		410	460	
Gravel & Water		460	495	

RECEIVED
MAY 08 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 495 feet
 _____ inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness 188
 Diameter From To
8 5/8 inches +1 feet 495 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 3/16 8 row
 From 455 feet to 475 feet
 From _____ feet to _____ feet

Date started February 28, 1991, 19____
 Date completed March 13, 1991, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 337 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick
 Contractor
 Address 1641 E. Sunset Rd. B116
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada contractor's driller's number issued by the Division of Water Resources 552
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V.H. Dimick
 By driller performing actual drilling on site or contractor
 Date May 7, 1991