


WELL DRILLERS REPORT

Please complete this form in its entirety



Log No. 54464
Permit No. 212
Basin 212

1. OWNER Herb Ott (Joyce Lombard) ADDRESS 6585 W. Spring Ave. Las Vegas, Nv.

2. LOCATION SE 1/4 SW 1/4 Sec. 14 T. 22 N/S R. 60 E. Clark County
PERMIT NO. NW SE

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Cemented gravel and rock		2	140	138
Conglomerate		140	250	110
Cemented gravel		250	360	110
Loose cemented gravel	360	360	375	15
Cemented gravel and boulders with loose areas		375	500	125

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 500 feet
Casing record 8 5/8" O.D. - 0 to 500'
Weight per foot 13# Thickness .135
Diameter 8 5/8 inches From 0 feet To 500 feet
Surface seal: Yes No Type Cemented
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from feet to feet
Perforations:
Type perforation Vertical Slot
Size perforation 1/4" x 6"
From 420 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet

RECEIVED
NOV 18 1976
Div. of Water Resources
Branch Office - Las Vegas, Nev.

Date started 2/10, 1976
Date completed 8/20, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
Static water level 340 Feet below land surface
Flow G.P.M.
Water temperature 67 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WEIMER DRILLING
Address 9051 S. Mohawk St. Las Vegas, Nv. 89118
Nevada contractor's license number 5962A
Nevada driller's license number 171
Signed H. V. Weimer
Date 11-17-76

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours