WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54939
Permit No.
Basin 145

NOTICE OF INTENT NO. 28054

1. OWNER Pat & Jay Gallagher (Blades Const)
MAILING ADDRESS 2988 Pine Valley Rd. Gardnerville NV. 89410
ADDRESS AT WELL LOCATION 2988 Pine Valley Rd Gardnerville NV. 89410

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 11 N/S R. 21 E Douglas County
PERMIT NO. (Issued by Water Resources) 35-310-51 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Hard Pack		0	8	8
Coarse Gravels		8	36	28
Coarse Volcanic Sands		36	95	59
Brown Clay		95	103	8
Very Hard Volcanic		103	195	92
Broken Fracture	x	195	206	11
Hard Volcanic		206	245	39
Broken Fractures	xxx	245	280	35

RECEIVED 96 SEP 23 AM 10:1 STATE ENGINEER'S OFFICE

Date started 9-3, 1996
Date completed 9-9, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	135	Feet
8 3/4	Inches	135	Feet	280	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	280

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 55 feet to 280 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H pump Company (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 9-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627