WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54993
Permit No.
Basin 162

NOTICE OF INTENT NO. 14936

1. OWNER David Wessling
MAILING ADDRESS 4400 E Wiley Circle
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4400 E. Wiley Circle

2. LOCATION NW 1/4 SE 1/4 Sec. 17 T 21S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources | 45-181-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark brown silty loam		0	19	19
Brown calichia		19	36	17
Grey calichia		36	56	20
Dark grey clay		56	74	18
Light brown clay	x	74	92	18
Light brown clay	x	92	113	21
Brown clay	x	113	130	17
Gravel	x	130	148	18
Light brown clay	x	148	165	17

LAS VEGAS OFFICE
OCT 4 1996
RECEIVED
DCNR/DWR

Date started 8/27/96, 19__
Date completed 8/28/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	165	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	165

Perforations:
Type perforation torch
Size perforation .25 x 6
From 130 feet to 145 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 2301 Winery Road, Suite 2
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Gary Strickland
By driller performing actual drilling on-site or contractor
Date 10.3.96