

OFFICE USE ONLY  
 Log No. 55022  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 31908

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER B+C BUILDERS SUPPLY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 543 OVERMETER RD SPANISH \_\_\_\_\_  
NV \_\_\_\_\_

2. LOCATION SW 1/4 SW 1/4 Sec 9 T 19 N/S R 20 E WASHOE County \_\_\_\_\_  
 PERMIT NO. OLD 11/00951A Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other ART

6. LITHOLOGIC LOG mw #1

Material	Water Strata	From	To	Thickness
<u>ON 10/24/95</u>				
<u>I FOUND THE</u>				
<u>MONITORING WELL</u>				
<u>TO BE IN GOOD</u>				
<u>SHAPE. I THEN</u>				
<u>PROCEEDED TO</u>				
<u>DRILL THE PVC</u>				
<u>CASING OUT TO</u>				
<u>43 FEET. I THEN</u>				
<u>PRESSURE GRouted,</u>				
<u>WITH NEAT</u>				
<u>CEMENT FROM</u>				
<u>43 FEET TO THE</u>				
<u>SURFACE.</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10' Inches To 0' Feet  
0' Inches Feet 43' Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>40 SCH</u>	<u>PVC</u>	<u>0'</u>	<u>43'</u>

Perforations:  
 Type perforation FACTOR 7  
 Size perforation 0.20  
 From 15' feet to 43' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 14  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From N/A feet to N/A feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality N/A

Date started 10/24, 1995  
 Date completed 10/24, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDREW EXPLORATION DRILLING Contractor  
 Address 1635 BELFORD RD. Contractor  
ZENO NV. 89509  
 Nevada contractor's license number 34525 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12/28/95