WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55024
Permit No.
Basin

NOTICE OF INTENT NO. 31908

1. OWNER B+C BUILDERS SUPPLY
MAILING ADDRESS 543 OVERMYER RD
SPARKS, NV.
ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ SW ¼ Sec. 9 T 19 N/S R 20 E WASHOE County
PERMIT NO. OCD M/O 0595 TA (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG MW #3

Material	Water Strata	From	To	Thickness
ON 10/24/95				
I FOUND THE				
MONITORING WELL				
TO BE IN GOOD				
CONDITION. I				
THEN PROCEEDED				
TO DRILL THE				
4" PVC CASING				
OUT TO 42'.				
I THEN				
PRESSURE GROUTED				
WITH NEAT				
CEMENT FROM				
42' TO SURFACE.				

Date started 10/24, 19 95
Date completed 10/24, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 42' Feet Depth Cased 42' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0' Feet	42' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	40	PVC	0'	42'

Perforations:
Type perforation FACTORY
Size perforation .020
From 15' feet to 42' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 42'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 24' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature 60°F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1135 BELFORD RD. (Contractor)
RENO, NV. 89504
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 12/28/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627