



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3428

1. OWNER Donald J. McDaniel ADDRESS AT WELL LOCATION 190 telegraph st Reno NV
 MAILING ADDRESS 1244 Sixth Street Santa Monica, CA
 2. LOCATION SE 1/4 NE 1/4 Sec 18 T 19 N R 20 E WASHOE County
 PERMIT NO. MC 694 694A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock
 4. SP PROPOSED USE
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>RUN A ROD</u>				
<u>Break BOTTOM END OFF OF PVC</u>				
<u>Run A ROD</u>				
<u>Fill PVC w/ cement FROM</u>				
<u>Bottom up</u>				
<u>Run PVC + FILL</u>				
<u>Run PVC</u>				
<u>TOP OFF TO GS</u>				

RECEIVED
 96 SEP 12 PM 4:12
 STATE ENGINEERS OFFICE

SP Spurge

SP-1

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 24.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8" Inches _____ Feet _____ Feet
 _____ Inches 0 Feet 25 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.37</u>			<u>0</u>	<u>6</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 6 feet to 24.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 24.5 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level: 15+- feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING INC. Contractor
 Address 75 Lewers creek RD Contractor
CARSON CITY NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller
 Signed John B. Deitch
 By driller performing actual drilling on site or contractor
 Date 4-12-96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 9-5 1996
 Date completed 9-5 1996