

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34629

1. OWNER FPA ADDRESS AT WELL LOCATION 1901 NATIONAL GUARD WAY
MAILING ADDRESS 10275 OLD PLACERVILLE RD Suite 16
SACRAMENTO, CA. RENO, NV
2. LOCATION 1/4 NW 1/4 Sec. 19 T. 19 N. R. 20 E. WASHOE County
PERMIT NO. MC1032 NE 015 210 26 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other ASA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------------------|--------------|------|----|------------|
| <u>RUN A ROD</u> | | | | |
| <u>BREAK BOTTOM AND OFF OF PUC</u> | | | | |
| <u>FILL PUC w/ cement</u> | | | | |
| <u>pull puc</u> | | | | |
| <u>pull puc</u> | | | | |
| <u>pull puc</u> | | | | |
| <u>TOP OFF TO GS</u> | | | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 20 Feet
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2.37</u> | | | <u>0</u> | <u>5</u> |

Perforations:
Type perforation 0.00
Size perforation SLOT

From _____ feet to _____ feet
From _____ feet to _____ feet
From 5 feet to 15 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 20 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 9-6 1996
Date completed 9-6 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |

9. WATER LEVEL
Static water level 60.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA Drilling Inc. Contractor
Address 75 Lewers Creek RD
CARSON CITY NV 89704 Contractor

Nevada contractor's license number 13697A
issued by the State Contractor's Board

Nevada driller's license number issued by the 1902
Division of Water Resources, the on-site driller

Signed John B. Smith
By driller performing actual drilling on site or contractor

Date 9-10-96

RECEIVED
96 SEP 12 PM 4 12
STATE ENGINEERS OFFICE

RUB #1