

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 85564

1. OWNER P.D.T.S (USA) INC ADDRESS AT WELL LOCATION Corte2 Gold mines  
 MAILING ADDRESS Hc66-50 Star Route Pipeline pit  
Beauregard, NV, 89821  
 2. LOCATION NW 1/4 NW 1/4 Sec. 5 T. 27 N. S. R. 47 E. LAND CO County  
 PERMIT NO. N 10-1003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALLUVIUM</u>		<u>0</u>	<u>500</u>	<u>500</u>
<u>NATIVE FILL</u>		<u>500</u>	<u>480</u>	<u>20</u>
<u>SAND PACK</u>		<u>480</u>	<u>380</u>	<u>100</u>
<u>Bentonite Slurry</u>		<u>380</u>	<u>180</u>	<u>200</u>
<u>Bentonite chips</u>		<u>180</u>	<u>52</u>	<u>128</u>
<u>Cement</u>		<u>52</u>	<u>0</u>	<u>52</u>

RECEIVED  
 96 SEP -3 PM 2:18  
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 500 Feet Depth Cased 475 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 20 Feet  
14 Inches  
 From 20 Feet To 500 Feet  
7/8 Inches  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>N/A</u>	<u>Sch 80</u>	<u>+2</u>	<u>475</u>

Perforations:  
 Type perforation 110v2  
 Size perforation .020  
 From Screen 475 feet to 415 feet  
 From Blank 415 feet to +2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 480 feet to 380 feet

9. WATER LEVEL  
 Static water level 192 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 92 °F Quality Clear

Date started 8/20 1996  
 Date completed 8/25 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>500</u>	<u>97</u>	<u>N/A</u>
			<u>1/2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EKLUND Drilling Co Contractor  
 Address P.O. Box 2748 Contractor  
2100, NV 89803  
 Nevada contractor's license number 0030823  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1942  
 Division of Water Resources, the on-site driller.  
 Signed William Riley  
 By driller performing actual drilling on site or contractor  
 Date 8/25/96