XX

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55088
Permit No.
Basin 108

NOTICE OF INTENT NO. 19149

1. OWNER Michael Hagen
MAILING ADDRESS 121 N. Calif. St.
Yerington, Nev 89447

ADDRESS AT WELL LOCATION
#21 Cottonwood
Yerington, Nev 89447

2. LOCATION NW ¼ SW ¼ Sec. 12 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-301-06 (Parcel No.) #14 Cottonwood Terrace Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	3	3
Fine Sand		3	12	9
Coarse Sand - Small Gravel		12	15	3
Clay - Small Gravel		15	18	3
Coarse Sand - Small Gravel		18	30	12
Small Gravel - Clay		30	37	7
Fine to Coarse Sand		37	59	22
Bluish Gray Clay - Coarse Sand		59	63	4
Coarse Sand - Gravel		63	68	5
Brown Clay		68	74	6
Coarse Sand - Gravel		74	82	8
Coarse Sand - Gravel - Rock		82	96	14
Clay - Small Gravel		96	104	8
Coarse Sand - Small Gravel		104	140	36
Coarse Sand - Gravel	X	140	159	19

Date started 8-17, 1994
Date completed 8-20, 1994

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	7	½ HR
AIR LIFT	100+	140' Line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	159

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	159

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 159 feet

9. WATER LEVEL
Static water level 28' 6"
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept. 9, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627