X 1.

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55089
Permit No.
Basin R-108

NOTICE OF INTENT NO. 24820

1. OWNER Ronald Moore
MAILING ADDRESS 268 Sunset Hills Drive Yerington Nev. 89447
ADDRESS AT WELL LOCATION 268 Sunset Hill Drive Yerington Nev. 89447

2. LOCATION N/E ¼ SW ¼ Sec. 20 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 14-251-15 (Parcel No.) none (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam some small rock		0	77	77
gravel + sand	yes	77	95	18
brown clay		95	120	25
granit gravel	yes	120	140	20

Date started Feb 25 1994, 1994
Date completed March 1 1994, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	50	4 hrs.

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	60 Feet
6 Inches	60 Feet	140 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8		188	0	140

Perforations:
Type perforation factory cut slott
Size perforation 3/32 X 3
From 120 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address Box 92 Smith Nev. 89430 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date March 8 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627