

OFFICE USE ONLY
 Log No. 55090
 Permit No. _____
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Doug & Beatrice Rossman ADDRESS AT WELL LOCATION 82 N. By Bee Lane
 MAILING ADDRESS P.O. Box 90994 Yerington Nev 89442
City of Industrial Cal. 91715
 2. LOCATION SW 1/4 NW 1/4 Sec 26 T 14 N R 26 E Lyon County
 PERMIT NO. 14-357-66
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	8	8
Clay - Coarse Sand				
Gravel - Fill		8	12	4
Sand - Gravel - Fill		12	65	53
Brown Clay - Coarse Sand		65	76	11
Brown Clay - Coarse Sand - Gravel		76	112	36
Coarse Sand - Gravel - Rock		112	142	30
Clay Strata		142	160	18
Coarse Sand - Gravel	X	160	170	10
Coarse Sand - Clay	X	170	176	6
Coarse Sand - Gravel	X	176	179	3

8. WELL CONSTRUCTION
 Depth Drilled 179 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 179 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>179</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/32 x 9" x 6 Rows
 From 159 feet to 179 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 179 feet

Date started 8-29, 1994
 Date completed 9-2, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>30</u>	<u>4</u>	<u>1/2 HR</u>

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. By Bee Lane Contractor
Yerington Nev 89442
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-27-94