WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 55092
Permit No. 36047
Basin 8-10C

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9119

1. OWNER Carson City Water Dept
MAILING ADDRESS 3300 Butti Way
Carson City, Nev 89701

ADDRESS AT WELL LOCATION
Lakeview Meadow Unit #3

2. LOCATION NW ¼ SW ¼ Sec 36 T 16 N/S R 19 E/W Carson City County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Completion log # 16562				
* Abandon Well				
Well was abandoned by perforating from 100' to 50' B.G.S.				
Holeplug and Neat Cement Grout were used to fill the well				
43 Bags Holeplug 125-205'				
52 Bags Cement 125' to Surface.				
Casing was cut off 5' below grade for final abandonment.				
- Original Drillers log attached.				

Date started 10-10, 1991
Date completed 10-12, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 220 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 5/8 inches	-5 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 (seal) 125 (plug) feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Mills Knife/Saw
Size perforation 1/4" x 1/16"
From 50 Mills feet to 100 feet
From 100 SW feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 9 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas M. Cox (Layne-Western) Contractor
Address Thomas M. Cox (PO Box 1326 Woodland Ca 95695) Contractor
Nevada contractor's license number issued by the State Contractor's Board 0019101 C57
Nevada contractor's driller's number issued by the Division of Water Resources 1572
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572
Signed Thomas M. Cox - Layne-Western Co
By driller performing actual drilling on site or contractor
Date 11-11-91

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85)