WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55297
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 25060

1. OWNER Kevin Paul
MAILING ADDRESS P.O. Box 2400, Fallon, NV 89407
ADDRESS AT WELL LOCATION 1050 Yeoman Lane, Fallon, NV 89406

PER Churchill County Assessors Office

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 19 N/S R. 29 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 07-471-59 | Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	16	6
Fine Brown Sand		16	30	14
Brown Clay		30	35	5
Coarse & Fine Sand		35	39	4
Fine Gray & Black Sand		39	45	6
Black Sandy Clay		45	50	5
Black & Gray Sand		50	75	25
Coarse Grey Sand		75	94	19
Coarse Fine Brown Sand	X	94	113	19

'93 NOV -8 P1:45 STATE ENGINEER

Date started 11/7, 19 93
Date completed 11/7/93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 113 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	113 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	108

Perforations:
Type perforation Stainless Steel Well Screen
Size perforation .020
From 108 feet to 113 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 113 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 11/08/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627