WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Wells 1-18

STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55139
Permit No.
Basin 212

NOTICE OF INTENT NO. 17490

1. OWNER Grove Construction
MAILING ADDRESS 4680 S. Polaris #300
Las Vegas, Nv 89103

ADDRESS AT WELL LOCATION Las Vegas Hilton-Star Trek
Project in Las Vegas

2. LOCATION NW ¼ NW ¼ Sec. 10 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. Dw 1051 (Issued by Water Resources) 161-10-302-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill & Asphlat | | 0 | 2 | 2 |
| silt Sand Gravel | | 2 | 7.5 | 5.5 |
| Partially cemented | | 7.5 | 8 | .5 |
| White Caly & Silt | | 8 | 12.5 | 4.5 |
| Brown Clay | | 12.5 | 16 | 3.5 |
| Clay & Gravel | | 16 | 23 | 7 |
| Brown Clay | | 23 | 30 | 7 |

CONFIDENTIAL MAY 31 1996 LAS VEGAS OFFICE

Date started 5/3/96, 19
Date completed 5/3/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | 1.250 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 1/4" x 2 1/2" x 3 rows @ 13
From 0 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627