WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 55286
Rec. 19
Well No. ..... H
Permit No. .....
Do not fill in

Owner: Delmont Short. Driller: Allen Water ~~Serv~~ Well Service.

Address: 1402 E. St. Louis St. Address: 911 So. Main Lic. No. 40

Location of well: ~~1/4 S~~ 1/4 Sec. 1, T. 21 ~~N~~/S, R. 60 E, in Clark County

or WestWind Road.

Water will be used for: Domestic Total depth of well: 250'

Size of drilled hole: 12" Weight of casing per linear foot: 14.87

Thickness of casing: 8 gauge Temp. of water:

Diameter and length of casing: 8/58" O.D. 0 to 250'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 76

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: 4/27/59 Date of completion of well: 5/20/59

Type of well rig: 72 Star cable tool.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	4	4	sandy silt.
4	12	8	caliche.
12	31	19	clay and gravel
31	37	6	caliche
37	41	4	cemented gravel
41	57	16	sandy clay
57	63	6	clay and gravel
63	71	8	caving sand.
71	83	12	cemented gravel
83	91	8	clay and gravel
91	109	18	red sand.
109	115	6	cemented gravel
115	126	11	clay and gravel
126	137	11	red sand
137	142	5	red clay
142	170	28	caving red sand.
170	181	11	cemented gravel
181	192	11	sticky red clay
192	196	4	water gravel
196	218	22	clay and gravel
218	223	5	water gravel
223	231	8	clay and gravel
231	239	8	water gravel
239	244	5	red clay
244	250	6	clay and gravel

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 192 to 196 ft.

Other aquifers: 126-137
142-170 218-223
231-239

First water at 126 feet.

Casing perforated
from 178 to 250 ft.

Size of perforations
1/4x6" 6 around on 12" centers

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" I.D.	0	250	250	gravel packed with 18 yards gravel, top 50 feet cemented in place.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed ALLEN WATER WELL SERVICE.
Well Driller

By Bertie O'Allen

License No. 40

Dated 10/20/59, 19.....

(Not to be filled in by Driller)