WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 55479
Rec. 19
Well No. ..... [redacted]
Permit No. .....
Do not fill in

Owner: Jim Kent Driller: Louis F. Evans

Address: 1913 South 11th. Street Las Vegas Nev. Address: 2020 Carroll N. Las Vegas Lic. No. 117

Location of well: N.W¼ S.W¼ Sec. 12, T21 N/S, R.60 E, in Clark County

or .....

Water will be used for: ~~Domestic~~ Total depth of well: 180 ft.

Size of drilled hole: 50 ft. 12 inch. 110 ft. 10 inch. 20 ft. 8 inch. hole Weight of casing per linear foot: 14.5 lbs.

Thickness of casing: 8 gagge Temp. of water .....

Diameter and length of casing: 8 inch. O.D. pipe 170 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface: 116 ft.

If flowing well describe control works .....
(Type and size of valve, etc.)

Date of commencement of well: Feb. 8, 1955 Date of completion of well: Feb. 15, 1955

Type of well rig: Armstrong

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	1	1	sandy clay
1	3	2	gyp
3	4	1	sandy clay
4	7	3	gyp
7	12	5	sandy clay
12	28	16	gravel
28	32	4	gray clay & gravel
32	36	4	gravel
36	43	7	gray clay & gravel
43	47	4	gravel
47	66	19	yellow clay
66	90	24	gray clay & gravel
90	94	4	" sandy clay
94	109	15	yellow clay
109	112	3	gravel
112	145	33	yellow clay & gravel
145	147	2	gravel (water)
147	168	21	yellow sandy clay
168	180	12	cement gravel (water)

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 168 to 180 ft.

Other aquifers: 145 to 147

First water at 145 feet.

Casing perforated

from 140 to 170 ft.

Size of perforations

¼ inch wide 3 inches long

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 inch.	0	170	170	gravel packed 110 ft.from 50 ft.to 160 ft. cemented 2 yds.cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans
Well Driller

By Louis F.Evans

License No. 117

Dated Feb.23, 19 55

(Not to be filled in by Driller)