WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 55739
Rec. ..... 19..
Well No. .....
Permit No. .....
Do not fill in

Owner: Margarita Bravo Driller: Effinger Bros.

Address: 402 McWilliams Street Address: 1001 Artesia Way Lic. No. 105

Location of well: ..... ¼ ..... ¼ Sec. ....., T. ..... N/S, R. ..... E, in Clark County

or W½SE¼SE¼ Section 14 T21S R61E

Water will be used for: Domestic Total depth of well: 200 feet

Size of drilled hole: 12 Inch Weight of casing per linear foot: 12.06 lbs.

Thickness of casing: 10 Guage Temp. of water: .....

Diameter and length of casing: 8 5/8"OD 200 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: .....

If nonflowing well give depth of standing water from surface: 12' from top of casing

If flowing well describe control works: .....
(Type and size of valve, etc.)

Date of commencement of well: May 21, 1955 Date of completion of well: May 27, 1955

Type of well rig: "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	17	17	Gravel
17	23	6	Cement Gravel
23	43	20	Red Sandy Clay
43	45	2	Cement Gravel
45	48	3	Gravel (Water)
48	60	12	Red Sandy Clay
60	73	23	Yellow Clay
73	101	28	White Clay
101	107	6	Gravel (Water)
107	123	16	Red Clay
123	130	3	Sandstone
130	153	23	Red Clay
153	165	12	Gravel (Water)
165	168	3	Red Clay
168	175	7	Sandstone
175	185	10	Red Clay
185	193	8	Gravel (Water)
193	200	7	Red Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 185 to 193 ft.

Other aquifers: 153-165, 101-107

First water at 45 feet.

Casing perforated
from 60 to 200 ft.

Size of perforations: 1/8" x 1½"

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
85/8"OD	0	200	200	Cemented from 0 to 50 feet Graveled packed from 50 to 200 feet 4½ yards of pea gravel 2 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By A F Effinger

License No. 105

Dated May 27, 19 55

(Not to be filled in by Driller)