WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 55936
Permit No.
Basin 092A

NOTICE OF INTENT NO. 31878

1. OWNER Stan Beni
MAILING ADDRESS 1505 Capistrano Drive
Sparks, Nevada 89436

ADDRESS AT WELL LOCATION 9675 Red Rock Road
Reno, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 21N N/S R. 18 East Washoe County
PERMIT NO. (Issued by Water Resources) 087-340-13 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	
Brown DG & Sand		6	20	
Gray Clay		20	35	
White & Gray				
Volcanic Rock		35	75	
Black & Gray Volcanic				
Gravels		75	95	
Black & White, Brown				
Fractured Granite		95	120	
Gray Clay		120	130	
Multi Colored				
Fractured Volcanic				
Rock		130	196	
Gray Clay w/Volcanic				
Gravel		196	260	
Multi Colored Volcanic				
Rock		260	275	
Black & White Granite				
w/Trace Gray Clay		275	348	
Gray Clay		348	390	
Multi Colored Volcanic				
Rock w/Trace Gray Clay		390	475	
Black & White				
Granite (med hard)	X	475	501	
Multi Colored Volcanic				
Rock w/Green Clay Sticky		501	525	
T.D. 525				

Date started January 4, 19 96
Date completed January 17, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		10 Hours

Seal Depth of 50 feet per Tom Gallagher State Water Resources.

8. WELL CONSTRUCTION
Depth Drilled 525 Feet Depth Cased 525 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	100 Feet
8-1/2 Inches		100 Feet	200 Feet
6-1/8 Inches		200 Feet	525 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1-1/2	198
5"	6.56	.188	185	525

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 180 feet to 160 feet
From 355 feet to 375 feet
From 505 feet to 525 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 198 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 1/2 Frazer Ave (Contractor)
Sparks, Nevada 89431
Nevada contractor's license number issued by the State Contractor's Board 035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date January 24, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627