


WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. **56043**
 Rec.....
 Well No.....
 Permit No. **19731**



Owner..... **John Angus** Driller..... **Effinger Bros.**
 Address..... **1027 Wengert Avenue** Address..... **1001 Artesia Way** Lic. No. **212**
 Location of well: $\frac{1}{4}$ Sec..... T..... N/S, R..... E, in..... County.....
 or..... **Section 26 T21S R61E** **Clark**
 Water will be used for..... **Domestic** **perm. 19731** Total depth of well..... **140 feet**
 Size of drilled hole..... **12 Inch** Weight of casing per linear foot..... **12.06 lbs.**
 Thickness of casing..... **10 Gauge** Temp. of water.....
 Diameter and length of casing..... **8"OD** **160 feet**
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure..... **29' 7" from top of casing**
 If nonflowing well give depth of standing water from surface.....
 If flowing well describe control works.....
 Date of commencement of well..... **September 23, 1955** (Type and size of valve, e.....) **September 26, 1955**
 Date of completion of well.....
 Type of well rig..... **"71 Speed Star"**

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	2	2	Sand
2	7	5	Gravel
7	18	11	Yellow Clay
18	21	3	Cement Gravel
21	38	17	Red Clay
38	45	7	Gravel (Water)
45	62	23	Red Clay
62	89	27	Sandstone
89	92	3	Limestone (Water)
92	107	15	Red Clay
107	109	2	Limestone (Water)
109	125	16	Red Clay
125	131	6	Yellow Clay
131	135	4	Limestone
135	140	5	Red Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
 from **131** to **135** ft.
 Other aquifers..... **107-109**
89-92

First water at..... **38** feet.

Casing perforated
 from **50** to **140** ft.

Size of perforations
1/8" X 12"



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	140	140	Cemented from 0 to 50 feet Graveled packed from 50 to 140 feet 4 yards of pea gravel 2 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By A. F. Effinger
License No. 212

Dated September 26, 1955

(Not to be filled in by Driller)
