

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56075  
 Rec. 7/12 1954  
 Well No. \_\_\_\_\_  
 Permit No. Domestic  
*Do not fill in*

Owner Wm. Griffin Driller Effinger Bros.

Address 2309 Santa Paula Drive Address 212 Anderson Lane Lic. No. 105

Location of well:  $\frac{1}{4}$   $\frac{1}{4}$  Sec. 26, T. 21N/S, R. 61E, in Clark County  
 or 1/2 S E 1/4 SW 1/4 NE 1/4

Water will be used for Domestic Total depth of well 210 feet

Size of drilled hole 10 inch Weight of casing per linear foot 13.01 lbs.

Thickness of casing 10 Gauge Temp. of water \_\_\_\_\_

Diameter and length of casing 8 5/8" OD 80 feet  
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure \_\_\_\_\_

If nonflowing well give depth of standing water from surface 20' 9" from top of casing

If flowing well describe control works \_\_\_\_\_  
 (Type and size of valve, etc.)

Date of commencement of well June 29, 1954 Date of completion of well July 1, 1954

Type of well rig "71 Speed Star"

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	Water-bearing Formation, Casing Perforations, Etc.
0	5	5	Sand	
5	24	19	Limestone	
24	32	8	Yellow Sandy Clay	
32	33	1	Sand (Water)	Chief aquifer (water-bearing formation) from <u>205</u> to <u>210</u> ft.
33	41	8	Yellow Clay	
41	47	6	Red Sandy Clay	Other aquifers <u>67-82</u> <u>82-88</u>
47	56	9	Limestone	
56	67	9	White & Brown Clay	
67	83	16	Limestone (Water)	
83	90	7	Red sandy clay	
98	105	7	Limestone	
105	118	13	Yellow Clay	
118	125	7	Limestone	
125	205	80	Red Sandy Clay	First water at <u>22</u> feet.
205	210	5	Gravel (Water)	Casing perforated from <u>40</u> to <u>80</u> ft.
				Size of perforations <u>1/8" x 12"</u>



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
3 5/8" ID	0	60	60	Cemented from 0 to 40 feet 1 1/2 yards of cement Graveled packed from 40 to 60 feet 2 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---



---

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.  
Well Driller

By *A. H. Effinger*  
License No. 105

Dated July 1, 1954, 19.....

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---