Log No. 56077
Rec. ..... 19.....
Well No. .....
Permit No. .....
Do not fill in

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: Leslie O. & Flora Dell Gunter Driller: Effinger Drilling & Pump Service

Address: 1808 Ferguson NLV Address: Box 579 City Lic. No. 212

Location of well: Gov't Lot 34 SE 1/4 SW 1/4 Sec. 26, T. 21 N/S, R 61 E, in Clark County

or Rawhide & Tamarus

Water will be used for: Domestic Total depth of well: 200 feet

Size of drilled hole: 12 inch Weight of casing per linear foot: .1414

Thickness of casing: .156 Temp. of water:

Diameter and length of casing: 8" ID 200 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 16'

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: November 16, 1963 Date of completion of well: November 20, 1963

Type of well rig: "72 Speedstar"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	Brown Sandy Clay
5	11	6	Calichie
11	18	7	Gyp & Gravel
18	29	11	Red Clay & Sandstone
29	30	1	Limestone (Water)
30	44	14	Red Clay
44	46	2	Sandstone
46	65	19	Red Clay
65	72	7	Limestone (Water)
72	76	4	Red Clay
76	78	2	Sandstone
78	89	11	Red Clay
89	112	23	Red Sandy Clay
112	114	2	Sandstone
114	118	4	Gravel (Water)
118	124	6	Red Clay
124	132	8	Limestone (Water)
132	151	19	Red Clay
151	172	21	Gravel (Water)
172	176	4	Sandstone
176	194	18	Sand & Gravel (Water)
194	200	6	Red Sticky Clay

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 176 to 194 ft.

Other aquifers: 151-172
124-132
114-118
65-72

First water at 29 feet.

Casing perforated

from 130 to 196 ft.

Size of perforations

1/8" X 12" Torch

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" ID	0	200	200	Cemented from 0 to 50 feet 1½ yards of cement Graveled packed from 50 to 195 feet 4½ yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump
Well Driller

By A. Effinger

License No. 212

Dated November 21, 19 63

(Not to be filled in by Driller)

RECEIVED
NOV 22 1963
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA