

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 56679  
 Rec. \_\_\_\_\_ 19\_\_\_\_  
 Well No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
*Do not fill*

Owner Robert P. Hampton & Theodore Dexter Driller Louis F. Evans

Address P.O. Box 3444 North Las Vegas, Nev. Address 2020 Carroll N. Las Vegas Lic. No. 117

Location of well: N. 1/4 S. 1/4 Sec. 26., T. 21N/S, R. 61E, in Clark County  
 or \_\_\_\_\_

Water will be used for Reorganized Church of Latter Day Saints Total depth of well 160 ft.

Size of drilled hole 50' 12" 110' 10" Weight of casing per linear foot 11 lbs.

Thickness of casing 10 ga. Temp. of water \_\_\_\_\_

Diameter and length of casing 8" O.D. 160 ft.  
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure \_\_\_\_\_

If nonflowing well give depth of standing water from surface 25 ft.

If flowing well describe control works \_\_\_\_\_  
 (Type and size of valve, etc.)

Date of commencement of well Nov. 6, 1959 Date of completion of well Nov. 13, 1959

Type of well rig Keystone

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	Water-bearing Formation, Casing Perforations, Etc.
0	5	5	brown sand	
5	15	10	cement gravel	
15	20	5	cl.iche	
20	26	6	white clay	
26	40	14	brown sandy clay (water)	Chief aquifer (water-bearing formation)
40	45	5	red clay & gravel (water)	from <u>37</u> to <u>132</u> ft.
45	52	7	brown sandy clay	Other aquifers <u>52 to 63</u>
52	63	11	light brown clay & gravel (water)	<u>132 to 141</u> <u>141 to 160</u>
63	87	24	brown sticky clay	
87	132	45	brown clay & gravel (water)	
132	141	9	gravel (water)	
141	160	19	brown clay & gravel (water)	
				First water at <u>28</u> feet.
				Casing perforated
				from <u>80</u> to <u>160</u> ft.
				Size of perforations
				<u>1/4"</u> wide <u>6"</u> long



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" O.D.	0	160	160	gravel packed 110 ft. from 50 ft. to 160ft. 4 yds. gravel cemented 50 ft. from 0 to 50 ft. 2 yds. cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---



---



---

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans  
Well Driller

By Louis F. Evans

License No. 117

Dated Dec 2, 1959

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---



---



---