

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56094
 Rec. _____
 Well No. _____
 Permit No. _____
 Do not fill in

1

ANDRESEN

Owner CLAUS B. LOWNEN Driller LOUIS F. EVANS

Address 1648 PRINCETON STREET NORTH LAS VEGAS NEVADA Address 2020 CARROLL N. LAS VEGAS Lic. No. 117

Location of well: S. E. 1/4 S. W. 1/4 Sec. 26, T. 21 N/S, R. 61 E, in CLARK County
 or _____

Water will be used for DOMESTIC Total depth of well 150 ft.

Size of drilled hole 50 ft. 12 inch. 100 ft. 10 inch. Weight of casing per linear foot 11 lbs.

Thickness of casing 10 gauge Temp. of water _____

Diameter and length of casing 8 inch. O.D. CASING 150 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure _____

If nonflowing well give depth of standing water from surface 8 1/2 ft.

If flowing well describe control works _____
(Type and size of valve, etc.)

Date of commencement of well JULY 22, 1955 Date of completion of well JULY 28, 1955

Type of well rig ARMSTRONG

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	2	2	sandy clay
2	12	10	gray clay
12	15	3	gyp
15	31	16	brown sandy clay
31	45	14	brown clay & gravel (water)
45	46	1	sand stone
46	62	16	gray clay
62	71	9	gray sandy clay
71	72	1	gravel
72	106	34	gray sandy clay
106	109	3	gravel (water)
109	130	21	yellow sandy clay
130	131	1	gravel (water)
131	144	13	yellow sandy clay
144	147	3	gravel (water)
147	150	3	yellow sandy clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 144 to 147 ft.

Other aquifers 106 to 109

130 to 131


First water at 31 feet.

Casing perforated

from 60 to 150 ft.

Size of perforations

1/4 inch wide 6 inches long



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 inch.	0	150	150	GRAVEL PACKED 100 ft. from 50 ft. to 150 ft. CEMENTED 2½ yds. cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans
Well Driller

By LOUIS F. EVANS

License No. 117

Dated JULY 28, 19 55

(Not to be filled in by Driller)
