

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56099  
 Rec. 19  
 Well No.             
 Permit No.             
*Do not fill in*

Owner John L. & Jacqueline Mongeot Driller Effinger Bros.  
 Address 496 Naples Drive Address Box 589 Lic. No. 212  
 Location of well: 1/4 NW 1/4 Sec. 26, T. 21 N/S, R. 61 E, in Clark County  
 or Bond Road  
 Water will be used for Domestic Total depth of well 160 feet  
 Size of drilled hole 12 Inch Weight of casing per linear foot 12.06 lbs.  
 Thickness of casing 10 Guage Temp. of water             
 Diameter and length of casing 8"OD 160 Feet  
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)  
 If flowing well give flow in c.f.s. or g.p.m. and pressure             
 If nonflowing well give depth of standing water from surface 23' from top of casing  
 If flowing well describe control works             
(Type and size of valve, etc.)  
 Date of commencement of well April 16, 1956 Date of completion of well April 12, 1956  
 Type of well rig "71 Speed Star"

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	Sandy Clay
3	7	4	Gyp
7	34	27	Red Clay & Gravel
34	35	1	Limestone (Water)
35	46	11	Red Clay & Gravel
46	49	3	Cement Gravel
49	63	14	White Clay
63	69	6	Brown Clay
69	72	3	Limestone (Water)
72	82	10	Brown Clay
82	85	3	White Sandy & Gravel (Water)
85	103	18	Red Clay
103	108	5	Sandy Clay
108	114	6	Red Clay
114	116	2	Gravel (Water)
116	130	14	Red Clay & Gravel
130	132	2	Limestone
132	152	20	Clay
152	155	3	Limestone (Water)
155	160	5	Red Clay

Water-bearing Formation, Casing Perforations, Etc.

---

Chief aquifer (water-bearing formation)  
 from 152 to 155 ft.  
 Other aquifers 114-116  
82-85  
69-72  
34-35

---

First water at 34 feet.

---

Casing perforated  
 from 60 to 160 ft.

---

Size of perforations  
1/8" X 20"

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

160 In. casing	8400 feet	160 feet	160 Length	Remarks—Seals, Grouting, Etc. Cemented from 0 to 50 feet Graveled packed from 50 to 160 feet 5 yards of pea gravel 2½ yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---



---

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed \_\_\_\_\_  
Well Driller

By \_\_\_\_\_ 212

April 21, License No. 56

Dated \_\_\_\_\_, 19 \_\_\_\_\_

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---



---