

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 56188  
 Rec. 19  
 Well No.             
 Permit No.             
*Do not fill in*

Owner S.A. Goldstein Driller O.M. Gullard  
 Address Landmark Plaza--Apt. L-2 Address 6044 Euclid Ave. Lic. No. 115  
 Location of well: SW <sup>NW</sup> 1/4 ~~SW~~ 1/4 Sec. 28, T. 21 N/S, R. 61 E, in Clark County  
 or Hacienda Road  
 Water will be used for Domestic purpose Total depth of well 302 ft.  
 Size of drilled hole 14" - 200' 10" - 103 ft. Weight of casing per linear foot             
 Thickness of casing 1/2" - 10" 188 wall - 8" Temp. of water             
 Diameter and length of casing 200 ft. - 10" 110 ft. - 8"  
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)  
 If flowing well give flow in c.f.s. or g.p.m. and pressure             
 If nonflowing well give depth of standing water from surface 18 ft.  
 If flowing well describe control works             
 (Type and size of valve, etc.)             
 Date of commencement of well 12-3-62 Date of completion of well 12-28-62  
 Type of well rig Cable tool

## LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	Fill Dirt
3	16	13	Brown Sandy Clay
16	17	1	Calechi
17	35	18	Light Brown Clay
35	36	1	Sand, Gravel--1st Water
36	185	149	Soft & Hard layers of clay 6" to 1 ft. apart
185	188	3	Sand, Gravel--2nd Water
188	197	9	Light Brown clay--caving in
197	276	79	Brown Clay
276	280	4	Sand, Gravel--3rd Water
280	283	22	Hard Brown clay

362

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)  
from 276 to 280 ft.

Other aquifers 35-36  
185-188

First water at 36 feet.

Casing perforated  
from 100 to 150 ft.  
225 to 250 ft.  
270 to 280

Size of perforations

1/4 x 6

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
10 <sup>th</sup> 8 <sup>th</sup>	0	200	200 110	Cemented 0 to 75 ft Pea gravel packed 75 to 190 ft.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---

**WELL DRILLER'S STATEMENT**

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed *[Signature]*  
Well Driller

By.....

License No. 115

Dated 5-18-63, 19.....

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---