WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56205
Rec. 6/23 1955
Well No.
Permit No.
Do not fill in

Owner: Foster H. Kruz Driller: S.E. McKinney & Son

Address: 1212 Maryland Parkway, Las Vegas Address: 1042 So. Main, L.V. Lic. No. 45

Location of well: NW¼ SW¼ Sec. 26, T. 21 N/S, R. 61 E, in Clark County

or E½ of SW¼ of NW¼ of NW¼ of SW¼ of Section 26, Twp. 21, Range 61

Water will be used for: Domestic Total depth of well: 130'

Size of drilled hole: 12" to 50, 10" to 130' Weight of casing per linear foot: 10 Guage

Thickness of casing: 10 Guage Temp. of water:

Diameter and length of casing: 8" I.D. to 130'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 10 ft.

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: May 26, 1955 Date of completion of well: June 1, 1955

Type of well rig: 72 Speed Star, spudder

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	4	4	Cemented gravel
4	10	6	Caliche
10	19	9	Caliche
19	22	3	Gravel water
22	34	12	Caliche
34	37	3	Gravel
37	58	21	Sand & Clay
58	61	3	Sand Water
61	82	21	Red Clay
82	85	3	Sand Stone Water
85	92	7	Red Sand & Clay
92	96	4	Red Sand Water
96	101	Red Clay	
101	105	4	Sand Stone Water
105	117	12	Red Clay
117	119	2	Red Sand water
119	124	5	Red Clay
124	127	3	Sand Stone water
127	130	3	Red Sand water

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 127 to 130 ft.

Other aquifers: 124' to 127'
117' to 119' - 58' to 61
101' to 105' - 19' to 22
92' to 96'
82' to 85'

First water at 19 feet.

Casing perforated
from 50 to 130 ft.

Size of perforations
3/16" x 10"

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" I.D.	0	130	130	8" casing cemented down to 50 ft with 1½ yds. concrete.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed 35 G.P.M. from 45'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed S.R. McKinney & Son
Well Driller

By S.R. McKinney

License No. 45

Dated June 20, 1955

(Not to be filled in by Driller)