WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56250
Permit No.
Basin 6.92 B

NOTICE OF INTENT NO. 29037 T

1. OWNER Robert Ince
MAILING ADDRESS 80 W. Arroyos
Reno, NV 89509

ADDRESS AT WELL LOCATION 11675 Fir Dr.

2. LOCATION SW 1/4 NE 1/4 Sec. 15 T 21N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) | 080-394-10 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [x] Deepen
- [ ] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [ ] Rotary
- [ ] RVC
- [x] Air
- [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tagged bottom at 129'.				
Multi-colored sand & gravel		129	180	51
Hard Quartz		180	182	2
MC Rock w/stain & fractures	x	182	229	47

Date started 7/1/96, 19__
Date completed 7/8/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		4 hours

8. WELL CONSTRUCTION

Depth Drilled 229 Feet Depth Cased 227 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	129 Feet	229 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	122	227

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 150 feet to 170 feet
From 207 feet to 227 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From ___ feet to ___ feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce Mackay
By driller performing actual drilling on-site or contractor

Date 7-11-96