DIVISION OF WATER RESOURCES

R.G.T

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY

Log No. 56261

Permit No. 491

Basin 24586/26803 16069/16070

1. OWNER TROPICANA ~~COUNTRY CLUB~~ ADDRESS TROPICANA AVE LV NEV 3801 L.V. BLVD SO

2. LOCATION ~~SW~~ NW ¼ ~~SW~~ NW ¼ Sec 28 T. 21 N/S R. 61 E. CLARK Cou

PERMIT NOS 24586/26803 (16069-16070)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☒ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY & GRAVEL		0	27	27
CALCHIE		27	32	5
PEA GRAVEL		32	40	8
BRN. SANDY CLAY		40	80	40
WATER GRAVEL	↘	80	92	12
BRN. CLAY & GRAVEL		92	130	38
CEMENTED GRAVEL	↘	130	138	8
BRN SANDY CLAY		138	165	27
COURSE GRAVEL	↘	165	175	10
BRN SANDY CLAY		175	220	45
COURSE GRAVEL	↘	220	232	12
BRN CLAY & GRAVEL		232	320	88
COURSE GRAVEL	↘	320	328	8
BRN SANDY CLAY		328	370	42
BRN CLAY & GRAVEL		370	398	28
RED CLAY & SCHALE		398	485	87
BRN SANDY CLAY & GRAVEL		485	550	65
COURSE GRAVEL	↘	550	564	14
CEMENTED CONGLOMERATE	↘	564	590	26
RED SANDY CLAY		590	610	20
COURSE GRAVEL	↘	610	632	22
CEMENTED CONGLOMERATE	↘	632	670	38
SANDY CLAY		670	710	40
RED SITCKEY CLAY		710	735	25
RED CLAY & GRAVEL		735	775	40
RED SANDY CLAY		775	800	25

Date started 3-2-, 1977

Date completed 10-24, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED

Div. of Water Resources

Branch Office — Las Vegas, Nev.

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours

G.P.M. ..... Draw down ..... feet ..... hours

G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 20 inches Total depth 800 f

Casing record 20" ¼ WALL & 10" ¼ WALL

Weight per foot 52 + 26 Thickness ¼

Diameter	From	To
20 inches	0 feet	50 f
10 3/4" inches	0 feet	632 f
8 5/8 inches	620 feet	800 f
inches	feet	f
inches	feet	f
inches	feet	f

Surface seal: Yes ☒ No ☐ Type CEMENT

Depth of seal 50 f

Gravel packed: Yes ☒ No ☐

Gravel packed from 0 feet to 630 f

Perforations:

Type perforation MACHINE

Size perforation 1/8" x 2 1/4 10 ROWS

From 32 feet to 632 f

From 620 feet to 795 f

From ..... feet to ..... f

From ..... feet to ..... f

From ..... feet to ..... f

9. WATER LEVEL

Static water level 30 Feet below land surface

Flow ..... G.P.M.

Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true the best of my knowledge.

Name Allen Water Well Service

Address Box 15149 Las Vegas Nev 8911

Nevada contractor's license number 5095

Nevada driller's license number 40

Signed Fred B. Allen

Date 12-15-77