5 x

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 56297
Rec. 19
Well No. .....
Permit No. .....
Do not fill in

Owner Rev. Thomas Daly Driller S.R. McKinney & Sons, Inc.

Address 322 South 4th St., L.V. Address 1042 South Main Lic. No. 45

Location of well: SE¼ SE¼ Sec. 32, T21 N/S, R 61E, in Clark County

or .....

Water will be used for Domestic Total depth of well 272 feet

Size of drilled hole 12" to 50', 10" to 272' Weight of casing per linear foot 10 gauge

Thickness of casing 10 gauge Temp. of water .....

Diameter and length of casing 8" ID 16# from 0' to 272'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface 85'

If flowing well describe control works .....
(Type and size of valve, etc.)

Date of commencement of well 8/9/62 Date of completion of well 5/15/62

Type of well rig Bucyrus Erie 22W

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	10	10	clay & gravel
10	14	4	sand rock
14	25	11	clay & gravel
25	45	20	red sandy clay
45	55	10	caliche
55	72	17	sandy clay
72	80	8	red sand rock
80	85	5	clay
85	95	10	red sand rock (water)
95	160	65	clay & gravel (water)
160	205	45	brown sandy clay & gravel (water)
205	210	5	clay & gravel
210	222	12	cement gravel
222	242	20	cement gravel with clay streaks (water)
242	270	30	cement gravel (water)
270	272	2	cement gravel

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 240 to 270 ft.

Other aquifers 85 to 95'
95 to 160'
160 to 205'
222 to 240'

First water at 85 feet.

Casing perforated

from 110 to 270' ft.

Size of perforations

3/16" X 10"

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"ID	0	272	272'	Cemented casing in place with 2 yards of well grout at 50 feet.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed 50 GPM from 103 feet.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

S.R. McKinney & Sons, Inc.

Signed [illegible]
Well Driller

By J.L. McKinney

License No. 45

Dated 10/23, 1962

(Not to be filled in by Driller)