Log No. 56384
Rec. 19
Well No.
Permit No.
Do not fill in

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: WILLARD F. GOODFELLOW Driller: LOUIS F. EVANS

Address: RT.1 BOX 193 LAS VEGAS,NEVADA Address: 2020 CARROLL N.LAS VEGAS Lic. No. 117

Location of well: N.E.¼ ~~NW~~ N ¼ Sec. 34, T. 21 N/S, R. 61 E, in CLARK County

or

Water will be used for: DOMESTIC Total depth of well: 200 ft.

Size of drilled hole: 50' 12" 150' 10" Weight of casing per linear foot: 16.90 lbs.

Thickness of casing: 3/16 wall Temp. of water:

Diameter and length of casing: 8 5/8" O.D. 200 Ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 7 ft.

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: AUG. 24,1961 Date of completion of well: SEPT. 2,1961

Type of well rig: KEYSTONE

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	soil
3	7	4	gravel
7	12	5	hard cliche & rock
12	15	3	gravel
15	22	7	hard cliche & rock
22	50	28	white clay (water)
50	55	5	hard cliche & rock
55	60	5	red clay
60	65	5	hard cliche & rock
65	120	55	red clay & gravel
120	125	5	gravel (water)
125	180	55	red clay
180	185	5	hard cemented gravel (water)
185	187	2	red clay
187	190	3	hard cemented gravel (water)
190	191	1	red clay
191	195	4	hard cemented gravel (water)
195	196	1	red clay
196	198	2	hard cemented gravel (water)
198	200	2	clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 191 to 195 ft.

Other aquifers: 30 to 50
120 to 125 180 to 185
187 to 190 196 to 198

First water at 30 feet.

Casing perforated
from 60 to 200 ft.

Size of perforations
¼" wide 6" long

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 5/8"	0	200	200	gravel packed 150 ft.from 50 ft.to 200 ft. 5 yds.gravel cemented 50 ft.from 0 to 50 ft.2 ¼ yds.cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans
Well Driller

By LOUIS F.EVANS

License No. 117

Dated SEPT. 12, 19 61

(Not to be filled in by Driller)