WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56483
Rec.
Well No.
Permit No.
Do not fill in

Owner: Garl L. Ayers
Driller: Effinger Bros.
Address: 1505 South Main Street
Address: 1001 Artesia Way
Lic. No. 212

Location of well: ¼ ¼ Sec. , T. N/S, R. E, in Clark County

or W½S½N½NE¼SE¼NW¼ Section 35 T21S R61E Oqendo Drive

Water will be used for: Domestic
Total depth of well: 200 feet

Size of drilled hole: 12 Inch
Weight of casing per linear foot: 12.06 lbs.

Thickness of casing: 10 Guage
Temp. of water:

Diameter and length of casing: 8"OD 200 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 10 3/10' from top of casing

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: December 19, 1955
Date of completion of well: December 22, 1955

Type of well rig: "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	6	6	Yellow Sandy Clay & Gravel
6	11	5	Gyp
11	15	4	White Clay
15	23	8	Red Clay & Gravel
23	28	5	Yellow Clay
28	34	6	Limestone (Wqter)
34	43	9	Red Clay
43	49	6	Yellow Clay
49	52	3	Limestone (Water)
52	75	23	Yellow Clay
75	79	4	Limestone (Water)
79	113	34	Red Clay
113	116	3	Sandstone (Water)
116	140	24	Red Clay
140	142	2	Sandstone
142	154	12	Red Clay
154	156	2	Limestone (Water)
156	162	6	Red Sticky Clay
162	177	15	Gravel (Water)
177	185	8	Red Clay
185	188	3	Sandstone (Water)
188	200	12	Red Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 185 to 188 ft.

Other aquifers: 162-177, 154-156, 113-116, 75-79, 49-52

First water at 28 feet.

Casing perforated
from 80 to 200 ft.

Size of perforations: 1/8" x 20"

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	200	200	Cemented from 0 to 54 feet 3 yards of cement Graveled packed from 54 to 200 feet 6½ yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By

License No. 212

Dated December 22, 19 55

(Not to be filled in by Driller)