

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56506
 Rec. 19
 Well No. _____
 Permit No. _____
Do not fill in

Owner Mida Mae Dick (Bart. Houde) Driller Effinger Bros.
 Address Rt. 1, Box 250 City _____ Address 212 Anderson Lane Lic. No. 105
 Location of well: 1/4 Sec., T. N/S, R. E, in Clark County
 or SE 1/4 SW 1/4 NE 1/4 Section 35 T21S R61E
 Water will be used for Domestic Total depth of well 180 feet
 Size of drilled hole 12 Inch Weight of casing per linear foot 12.06 lbs.
 Thickness of casing 10 Gauge Temp. of water _____
 Diameter and length of casing 8 5/8" OD 180 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure _____
 If nonflowing well give depth of standing water from surface 51 from top of casing
 If flowing well describe control works _____
(Type and size of valve, etc.)
 Date of commencement of well February 16, 1955 Date of completion of well February 21, 1955
 Type of well rig "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	8	8	Yellow Sandy Clay & Gravel
8	21	13	Cement Gravel
21	34	13	Red Clay
34	36	2	Sandstone
36	47	11	Red Clay
47	49	2	Sandstone (Water)
49	56	7	Sticky Clay
56	69	13	Clay
69	73	4	Sandstone
73	76	3	Sand (Water)
76	81	5	Clay
81	83	2	Sandstone
83	97	14	Clay
97	98	1	Sandstone
98	105	7	Sticky Clay
105	117	12	Clay
117	118	1	Sandstone
118	120	2	Clay
120	143	23	Sandstone
143	152	9	Clay
152	161	9	Sandstone
161	165	4	Clay
165	169	4	Sandstone (Water)
169	177	8	Clay
177	180	3	Sandstone (Water)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 177 to 180 ft.

Other aquifers 165-169
73-76

First water at 47 feet.

Casing perforated
from 50 to 180 ft.

Size of perforations
1/8" X 12"

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
85/8"OD	0	180	180	Cemented from 0 to 50 feet Graveled packed from 50 to 180 feet 5 yards of pea gravel 1 1/2 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By *A. F. Effinger*

License No. 125

Dated February 21, 1955

(Not to be filled in by Driller)
