WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56648
Permit No.
Basin 094

NOTICE OF INTENT NO. 3[illegible]637

1. OWNER ROCKEY & TERRI PEFLEY
MAILING ADDRESS 15034 Red Rock Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-371-19 (Parcel No.) Red Rock Estates #77 Parcel 3B (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown sandy clay		3	11	8
Cemented granite sands		11	19	8
Brown sandy clay		19	31	12
Brown clay		31	90	59
Soft zone (NO WATER)		90	91	1
Brown sandy clay		91	130	39
Soft zone (app 1 GPM)	X	130	134	4
Brown sandy clays		134	205	71
Soft zone (app 3 GPM)	X	205	215	10
Brown sandy clay		215	249	34
Green sandy clay		249	251	2
Soft zone (app 4 GPM)	X	251	256	5
Green sandy clay		256	275	9

Date started 7-22-96, 19
Date completed 7-23-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	275	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 175 feet to 195 feet
From 215 feet to 235 feet
From 250 feet to 270 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. 8 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 25, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627